

From Email Dated October 12, 2006 Sent to Aaron Noble & Richard Conrad

Mr. Conrad and/or Mr. Noble,

I was reading through the proposed revisions to the accessibility provisions of the CBC and had a couple of questions concerning the revisions based upon the DOJ's certification comments. The two of you are listed as contacts for questions on the Notice of Proposed Changes. I would appreciate if one of you or someone from your office could help clarify a few questions I have.

DOJ Certification Revisions:

1. Section 1115B.3.1 (4.5) Concerning clearances at multiple occupant stall doors. This section now includes a reference to section 1133.B.2.4.2 and .3 which deal with door maneuvering clearances. However, the referenced restroom Figure 11B-1B shows a front approach stall door that does not have the required maneuvering clearance on the pull side extending 60" back from the door. Aren't the new stall door requirements and this figure in conflict?
2. Telephones - Section 1117B.2.7 (1) states that the pay phone enclosure must be at least 27" clear. However the revised Figure 11B-4 shows that it can be a maximum of 27". Aren't these in conflict?
3. Pedestrian Ramps - Does the revision to section 1133B.5.4.6 where it now states that "if ramps change direction at landings....." open way for ramps to be curved or angular without intermediate landings as long as they satisfy all of the other requirements for slope and length?

I appreciate your help.

Neal Casper
Casper Development Resources, Inc
6405 Lake Kathleen Avenue
San Diego, CA 92119
619-741-2062 fax
619-741-1080 office